


Approved For Release 2003/06/20 : CIA-RDP78T05161A001100010048-5



25X1 25X1

CIA IMAGERY ANALYSIS DIVISION

25X1

CHINESE POWER PLANTS

LIAONING PROVINCE


- (A) An-shan Thermal Power Plant (Iron and Steel Combine)
- (B) Chin-chou Thermal Power Plant
- (C) Fou-hsin Thermal Power Plant
- (D) Fu-shun Thermal Power Plant (Liaoning)
- (E) Fu-shun Thermal Power Plant (Shale Oil Plant)
- (F) Fu-shun Hydro Power Plant (Ta-huo-fang)
- (G) Fu-shun Thermal Power Plant (Taikanton 1)
- (H) Huan-jen Hydro Power Plant
- (I) Kai-yuan Thermal Power Plant (Ch'ing-ho)
- (J) Lu-ta Thermal Power Plant (Amanogawa 1)
- (K) Lu-ta Thermal Power Plant (Kan-ching-tzu)
- (L) Pen-chi Thermal Power Plant No. 2
- (M) Pen-chi Thermal Power Plant No. 3
- (N) Shen-yang (Mukden) Thermal Power Plant
- (0) Shen-yang (Mukden) Thermal Power Plant NE
- (P) Supung-Nodongjagu Hydro Power Plant

REQUIREMENT

C-RR5-83,218

CIA/IAD PROJECT

30647-6



Δ


		CIA IMAGERY AN ALYSI	S DIVISION	
	(IR	AN THERMAL POV ON AND STEEL (NPIC NUMBER -	COMBINE)	
the southern s 41 07 55N - 12 conveyor syste stockpile may consists of ei gas holder, sm	ector of the A 2 59 05E. The m to the south indicate coal ght natural dr all gas holder s are located	n-shan Iron an plant is print west of the plant is a secondary aft cooling to, control hour	nd Steel Completerily gas oper Lant and the ary source of fur owers of variouse, sub-station	pparent coal
and four addit to the main se cables are not be transformer	ional small me ection. The ge visible leadi	tal stacks on merator hall ng to the con north of the	a smaller boi has four roof trol house or	ilerhouse section ler section contiguo sections. Power what appears to . However, smoke/
No new co	nstruction has	occurred dur	ing the specif	ied period

-1-

FIGURE 2

AN-SHAN THERMAL POWER PLANT (IRON AND STEEL COMBINE)





Λ	Lund For Bolon TOP, SECRET	 <mark> A-RDP78</mark> T05161A001100010048-5	
Appr	pved For Release 2003/06/20 TC	; <u> A-RDP78 </u> 05161A001100010048-5)

25X1 25X1

CIA IMAGERY ANALYSIS DIVISION

25X1

AN-SHAN THERMAL POWER PLANT (IRON AND STEEL COMBINE)

CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
None. Foundations is in place for additional cooling tower but is never completed.	Moderate smoke from stack A. There appear to be six or seven additional stacks in operation but smoke/vapor precludes analysis. Cooling towers A and B are observed but heavy vapor is rising from C with wisp of vapor from cooling tower H. Spray ponds are in operation.
None	Moderate smoke from stack A. Light smoke from stack K. Appears to be six or seven other stacks in operation but smoke/vapor precludes further analysis. Spray ponds are in operation.
None	Appears to be moderate smoke from stacks D, E, F, G, H, and J, but smoke precludes further analysis. Light vapor from cooling towers C, D, F, G, and H. Spray ponds are in operation.
None	Smoke/vapor precludes analysis of power plant. Light vapor from cooling towers A, B, C, D, and E. Spray ponds are in operation.
None	Smoke/vapor precludes analysis of stacks. Heavy vapor from cooling towers A, D, E, and H. Spray ponds are in operation.

-2-

25/1		
25X1	Approved For Releas Of GEGRET:	CIA-RDP78T05161A001100010048-5
25X1	CIA IMAGERY ANALYSIS	DIVISION
25X1	AN-SHAN THERMAL P (IRON AND STEEL	
	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
	None	Heavy smoke/vapor precluded further analysis. Spray ponds are in operation.
	None	Heavy smoke/vapor precluded further analysis. Spray ponds are in operation.
	None	Heavy smoke from what appears to be stacks A, C, D, E, F, G. Smoke/vapor precludes further analysis. Heavy vapor from cooling tower D. Moderate vapor from cooling tower C. Light vapor from cooling tower B. Smoke/vapor
		obscure cooling towers F, G, and H. Spray ponds are in operation.

B

	TOP SECRE Release 2003/06/20 : C		
	CHIN-CHOU THERMAL	POWER PLANT	
			rthwest of Chin-chou
n the Chin-chou Syn	thatic Fuels Plant	The second secon	\ - - -
The plant is rail-se	rved, apparently co	o <mark>al-</mark> operated a	nd includes a small sub-
The plant is rail-se station located east	rved, apparently co of the plant and t	oal-operated a two small octa	nd includes a small sub- gonal wooden cooling
The plant is rail-se station located east towers (A and B). I	rved, apparently co of the plant and t he power plant has	oal-operated a two small octa no coal handl	nd includes a small sub-
The plant is rail-se station located east towers (A and B). I	rved, apparently co of the plant and t he power plant has to a retort builds	oal-operated a two small octa no coal handl ing located to	nd includes a small sub- gonal wooden cooling ing equipment, but is
The plant is rail-sestation located east towers (A and B). Thinked by a conveyor coal conveying and t	rved, apparently co of the plant and the power plant has to a retort building reatment facilities	pal-operated a two small octa no coal handl ing located to	nd includes a small sub- gonal wooden cooling ing equipment, but is the north which contains
The plant is rail-sestation located east towers (A and B). I linked by a conveyor coal conveying and the powerhouse	rved, apparently co of the plant and the power plant has to a retort building reatment facilities consists of an olde	oal-operated a two small octa no coal handl ing located to s. er section whi	nd includes a small sub- gonal wooden cooling ing equipment, but is the north which contains ch probably contains
The plant is rail-sestation located east towers (A and B). I linked by a conveyor coal conveying and the powerhouse	rved, apparently co of the plant and the power plant has to a retort builds reatment facilities consists of an olde generator units and	pal-operated a two small octa no coal handl ing located to s. er section whi d a new sectio	nd includes a small sub- gonal wooden cooling ing equipment, but is the north which contains ch probably contains n, partially completed,
The plant is rail-se station located east towers (A and B). The Linked by a conveyor coal conveying and the powerhouse two operable boiler-which appears to control for the generator hall for the statement of the senerator statement of the state	rved, apparently co of the plant and the power plant has to a retort build reatment facilities consists of an olde generator units and tain one completed or this new section	cal-operated a two small octa no coal handling located to s. er section which a new section boiler unit so has not been	nd includes a small sub- gonal wooden cooling ing equipment, but is the north which contains ch probably contains n, partially completed, erviced by stack C. erected; however, the
The plant is rail-sestation located east towers (A and B). The linked by a conveyor coal conveying and the powerhouse two operable boiler-which appears to continue the generator hall from boiler unit is continued.	rved, apparently co of the plant and the power plant has to a retort building reatment facilities consists of an olde generator units and tain one completed or this new section connected to the exi	cal-operated a two small octa no coal handling located to s. er section which a new section boiler unit so has not been isting generat	nd includes a small subgonal wooden cooling ing equipment, but is the north which contains ch probably contains n, partially completed, erviced by stack C. erected; however, the or hall by a conduit
The plant is rail-se station located east towers (A and B). The Linked by a conveyor coal conveying and the powerhouse two operable boiler-which appears to control for the generator hall for the statement of the senerator statement of the state	rved, apparently co of the plant and the power plant has to a retort building reatment facilities consists of an olde generator units and tain one completed or this new section connected to the exi	cal-operated a two small octa no coal handling located to s. er section which a new section boiler unit so has not been isting generat	nd includes a small subgonal wooden cooling ing equipment, but is the north which contains ch probably contains n, partially completed, erviced by stack C. erected; however, the or hall by a conduit
The plant is rail-sestation located east towers (A and B). The linked by a conveyor coal conveying and the powerhouse two operable boiler-which appears to continue boiler unit is continued may be in serviced.	rved, apparently co of the plant and the power plant has to a retort building reatment facilities consists of an olde generator units and tain one completed or this new section connected to the exi	cal-operated a two small octa no coal handling located to s. er section which a new section boiler unit so has not been isting generat source of stea	nd includes a small subgonal wooden cooling ing equipment, but is the north which contains ch probably contains n, partially completed, erviced by stack C. erected; however, the or hall by a conduit m.

25X1





CHIN-CHOU THERMAL POWER PLANT



25X1



25X1

25X1 App

Approved For Release 2003/06/2015 CIA-RDP781 05161A001100010048-5

TOP SECRET Approved For Release 2003/06/20 : CIA-RDP78T05161A001100010048-5

25X1

25X1

CIA IMAGERY ANALYSIS DIVISION

CHIN-CHOU THERMAL POWER PLANT

-	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION	
	Construction on addition to boilerhouse - generator hall is apparently arrested.	No steam/vapor present.	
	None apparent.	Light smoke from stacks A and B.	
	None apparent.	No smoke/vapor observed.	
4			25>
	None apparent.	No smoke/vapor observed.	
- 		·	
-	None apparent.	No smoke/vapor observed.	
_			
_			
J			0.E.V

25X1
25X1
CIA IMAGERY ANALYSIS DIVISION
CHIN-CHOU THERMAL POWER PLANT

CONSTRUCTION ACTIVITY LEVEL OF PRODUCTION No smoke/vapor observed. None apparent. None apparent. Light smoke from stacks A and B. 25X1 No smoke/vapor observed. None apparent.

-6-

Approved For Release 2003/06/20 : CIA-RDP78T05161A001100010048-5

TOP SE(Approved For Release 2003/06/20	CRET	A001100010048-5	25X1
CIA IMAGERY A	AN ALYSIS DIVISION		25X1
			25X^
FOU-HSIN THER NPIC NUM	MAL POWER PLANT BER - 8-B		25X1


The Fou-hsin Thermal Power Plant is located in central Fou-hsin at coordinates 41 59 40N - 121 39 50E. The plant is rail-served, coal-operated and includes fourteen natural-draft, reinforced concrete/masonry cooling towers, two spray ponds, sub-station, control house and support/storage facilities.

Poor quality, small scale, or obliquity of existing photography preclude detailed analysis of this facility, however, there appears to be two or possibly three distinct powerhouses with a total of at least nine boiler-generator units. The western section is equipped with at least four metal roof-stacks (probably one per boiler-generator unit); the newer and larger section has two large masonry stacks (A and B) and probably contains three or four units. There may be a small powerhouse section (probably the original plant) between the two main sections. No power leads or other indicators of the number of generators could be identified.


The construction of cooling tower 0 was the only instance of new construction during the period 25X1



FOU-HSIN THERMAL POWER PLANT



25X1



25X1

CIA IMAGERY ANALYSIS DIVISION

25X1

FOU-HSIN THERMAL POWER PLANT

CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION	-
Foundations are in place for cooling towers N and O.	Moderate smoke from stacks A, B, C, D, E, and F. Light vapor from cooling towers A, B, C, D, E, F, G, H, I, J, K, and M. Six sprinklers are in operation in spray pond A. Three sprinklers are in operation in pond B.	
None	Moderate smoke from stack B. Light smoke from stack A. Light vapor from cooling towers E, F, G, H, I, K, and M. Six sprinklers in each spray pond are in operation.	-
None	Heavy smoke from stack A. Moderate smoke from stacks C, D, and F. Moderate vapor from cooling towers G, H, J, and L. Light vapor from cooling tower H.	25X1
None	Moderate smoke from stacks A, B, and D. Possible light smoke from stacks C, E, and F. Moderate vapor from cooling towers L and M. Light vapor from cooling towers A, B, C, D, E, F, G, H, I, J, K, and L.	÷
Cooling tower O is being completed.	Moderate smoke from stacks A, B, C, D, E, and F. Moderate vapor from cooling towers A, C, D, E, G, I, J, K, L, and M. Three spray units are in operation in each pond.	

25X1
25X1

25X1

CIA IMAGERY ANALYSIS DIVISION

FOU-HSIN THERMAL POWER PLANT

CONSTRUCTION ACTIVITY LEVEL OF PRODUCTION Light smoke from stacks A, B, C, None D, E, and F. Light vapor from cooling towers A, B, C, D, E, G, H, I, J, K, L, and M. Spray ponds don't appear to be in operation. None Heavy smoke from stacks A and B. Moderate smoke from stacks C, D, E, and F. Heavy vapor from cooling towers A, B, C, D, E, G, I, J, K, and M. Spray ponds appear to be in operation. Cooling tower O is completed. Heavy smoke from stack B. Light Site for cooling tower N smoke from stacks A, C, D, and E. 25X1 shows no progress. Light vapor from cooling towers A, C, E, G, I, J, K, and L. Wisp of smoke from cooling towers B, D, and F. Spray ponds appear frozen. None Heavy smoke from stack B. Moderate smoke from stacks A, D, E, and F. Light vapor from cooling towers B, E, G, I, J, K, and M.

Approved For Release 2003/06/20 : CIA-RDP78T05161A001100010048-5

Approved	TOP SECRET For Release 2003/06/20 : CIA-RI	DP78T05161	A001100010048-5	25X1
	CIA IMAGERY ANALYSIS D	UVISION		25X1
	CIA IMAGERT ANALTSIS D	77101013		0.E.V

FU-SHUN THERMAL POWER PLANT (LIAONING) NPIC NUMBER - 36-B1


25X1


The Fu-shun Thermal Power Plant (Liaoning) is located 2.2 nm north of the Ta-huo-fang Dam at the coordinates of 41 55 02N - 124 05 38E. The plant is rail served and coal operated. It includes a sub-station, control house, maintenance building, six small oil storage tanks, and numerous support/storage buildings. There are no transformers visible in the sub-station indicating that the power is utilized locally. Cooling water is evidently obtained from the small canals located near the substation; no cooling towers or spray ponds have been constructed.

The boiler house appears to contain thirteen operable boiler units serviced by three masonery stacks. The southwest end of the boiler house and generator hall is unfinished and will probably be expanded to house an additional boiler unit for a total of fourteen.

The generator hall is compartmented into seven sections, each in line with two boiler units. No power leads could be detected between the generator hall and sub-station. There are, however, four sets of transmission towers which lead from the generator hall in a northwest direction.


New construction period consisted of the installation of five sets of dust catchers and completion of three flue systems in the boiler house section serviced by stack C.





FU-SHUN THERMAL POWER PLANT (LIAONING)

25X1



25X1 Approved For Release 2000 65 CREA RDP78T05161A001100010048-5 25X1 CIA IMAGERY ANALYSIS DIVISION 25X1 FU-SHUN THERMAL POWER PLANT (LIAONING) CONSTRUCTION ACTIVITY LEVEL OF PRODUCTION Construction is occurring Heavy smoke from stack B. on the five boiler units served by stack C (See Figure 1). Obliquity precluded Heavy smoke from stacks A and B. analysis. 25X1 Obliquity precluded Heavy smoke from stacks A and B. analysis. Undeterminable; however, Heavy smoke from all three stacks. three boiler units were probably completed as indicated by heavy smoke from stack C. Undeterminable due to smoke / Heavy smoke from stack B with light haze over plant. smoke over stack C.

25X1

Approved For Release 2003/06/20 ; GIA-RDP78T05161A001100010048-5

TOP SECRET Approved For Release 2003/06/20 : CIA+RDP78T05161A00110	00010048-5	25X
CIA IMAGERY ANALYSIS DIVISION		25X

FU-SHUN THERMAL POWER PLANT (LIAONING)

_				
_		CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION	
-		Two southern most boiler units were not observed connected to stack C.	Heavy smoke from stacks A and B.	
		Obliquity precluded analysis.	Moderate smoke from stack B.	
: , 				25X1
		Undeterminable due to heavy smoke/haze over plant.	Heavy smoke from all three stacks.	
		All five boiler sections are now connected to stack C. No apparent construction on sixth boiler unit.	Heavy smoke from all three stacks.	
		·		
-	ŀ	-12 -		

FU-SHUN THERMAL POWER PLANT (SHALE OIL PLANT) NPIC NUMBER - 36-G1

25X1

The Fu-shun Thermal Power Plant (Shale Oil Plant) is located in the southeast sector of the shale oil plant in eastern Fu-shun at coordinates 41 49 50N - 124 02 50E. The facility is rail served, coal operated, and consists of a coal car unloading building, coal conveyor system, control house with two visible transformers, two natural draft masonery cooling towers, pumphouses, and several small tanks (which probably are utilized for oil storage). A steam line extends from the eastern end of the building and services various buildings in the shale oil plant.

There are four sets of flues - each containing four ducts which connect the boiler house to the large masonery stack. Four dust-catcher units are also present suggesting that four boiler units are present. Power cables leading from the generator hall to the control house are not evident although four sets of probable power lead terminals can be seen on the control house wall facing the generator hall.




25X1

25X1


Approved For Release 2003 TOB/SECRET A-RDP78 T 05161A001100010048-5

FU-SHUN THERMAL POWER PLANT (SHALE OIL PLANT)

FIGURE 7



25X1



25X1

Approved For Release 2003/06/2014-RDP78T05 61A001100010048-5

25X1

25X1

25X1

CIA IMAGERY ANALYSIS DIVISION

FU-SHUN THERMAL POWER PLANT (SHALE OIL PLANT)

•	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
	None	Very light smoke is seen above the stack. No vapor is visible from the cooling tower A but moderate vapor is visible above B.
	None	Heavy smoke is observed from the stack. Heavy vapor is visible over the cooling tower labeled B. Whisp of vapor is seen over cooling tower labeled A.
		25X1
:	None	No smoke or vapor observed.
	None	Heavy smoke is observed from the stack. Heavy vapor from cooling tower B.
	None	Heavy smoke from stack. Heavy vapor from cooling tower B.
:		

25X1 25X1	Approved For Release 2008/08/26/14-RDP78T05161A001100010048-5	
	CIA IMAGERY ANALYSIS DIVISION	
25X1	FU-SHUN THERMAL POWER PLANT (SHALE OIL PLANT) •	

FU-SHOW THERMAL POWER PLANT (SHALE OIL PLANT)

	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
	None	Not in operation.
	None	Not in operation.
5X1	None	Not in operation.
	None	Not in operation
	None	Light smoke coming from the stack. Light possible vapor is coming from both cooling towers.
	-14-	

25X1

Approved For Release 13963 1962 E FIA-RDP78T05161A001100010048-5

F

	CIA IMAGERY ANALYSIS DIVIS	ON	
FU-S	HUN HYDRO POWER PLANT (TA NPIC NUMBER - 36-J	-HUO-FANG)	
of the Fu-shun Reser	ro Power Plant (Ta-huo-fa voir at coordinates 41 53 intake control house, un	05N - 124 05 30. derground condui	E. The ts and pen-
tocks, spillway out ub-station. There	let west of the generator are no transformers visib	hall, and a sma Le, indicating th	nat power is
stocks, spillway out sub-station. There stilized locally. Water is appare	let west of the generator are no transformers visib ntly carried by two under the generator hall which	Le, indicating the conduits	nat power is to a surge-
stocks, spillway out sub-station. There stilized locally. Water is appare tank and finally to sets of outlets.	are no transformers visib ntly carried by two under	Le, indicating the conduits of the contact to contact t	nat power is to a surge- in two

25X1

25X1

Approved For Release 2003/080/2/05E0REA RDP78T05161A001100010048-5

FIGURE 8

FU-SHUN HYDRO POWER PLANT (TA-HUO-FANG)



25X1

25X1

TOP SECRET | Approved For Release 2003/06/20 : CIA RDP78T05161A001100010048-5

25X1

25X1

25X1

CIA IMAGERY ANALYSIS DIVISION

FU-SHUN HYDRO POWER PLANT (TA-HUO-FANG)

	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
	None	Turbulence noted; appears to be from both outlets.
-		
	None	Heavy turbulence from western outlet.
		: :
	None	Oblique coverage precluded detection of turbulence.
		25X1
- ;	None	Apparent turbulence from eastern outlet.
	None	No turbulence apparent; however, water in front of the outlets is
		free of ice.
	-17-	25X1

CIA IMAGERY ANALYSIS I	DIVISION
FU-SHUN HYDRO POWER PLANT	I (TA-HUO-FANG)
CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
None	Turbulence noted from one and possibly both outlets.
None	Turbulence observed from apparent one outlet; possibly eastern.
None	No turbulence observed; however, water at outlets is free of ice.
·	

Approved For Release 2003/06/20:

Approved For Release 2003/06/20 : CIA-RDP78T05161A001100010048-5

G

ISION
'(TAIKANTON 1)
I
I

The older and smaller plant is located in the eastern section of the complex, and probably has two boiler units and two and possibly three generators. The larger plant is of two distinct designs. The eastern section is served by eight short and three taller metal stacks, and probably contains eleven boiler-generator units. The western section of the larger plant has four dust catcher units serviced by a single free-standing masonery stack. The generator hall, however, does not extend the full length of the combined boilerhouses, making it unlikely that at least two of the four boiler units are connected to generators.

			_			
There has	been n	o change	or	new	construction	




25X1

25X1

Approved For Release 2003 TOB / 25CRETIA-RDP78 T05161A001100010048-5

FIGURE 9

FU-SHUN THERMAL POWER PLANT TAIKANTON 1



25X1

25X1

25X1

25X1

CIA IMAGERY ANALYSIS DIVISION

FU-SHUN THERMAL POWER PLANT (TAIKANTON 1)

1	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
	None	Appears as if all the stacks are smoking (poor quality coverage precludes analysis). Heavy vapor from cooling towers C, D, E, F, G, and H. Light vapor from cooling tower A. Spray ponds are activated.
	None	Heavy smoke from stack A. Moderate smoke from stacks B, C, F, G, and M. Apparent light smoke from stacks D and E. Light vapor from cooling towers A, B, C, D, E, F, G, I, K, L, and M. Spray ponds appear to be in operation.
	None	Heavy smoke from stacks A, B, C, D, E, and F. Moderate smoke from stacks H and L. Cooling towers are obscured by smoke/vapor. Spray ponds A and B are in operation. Spray ponds C and D are frozen.
		20/(1
-		
: ₩		
-		

25X	1
25X1	١

Approved For Release 108/05/2014-RDP78T05161A001100010048-5

CIA IMAGERY ANALYSIS DIVISION

FU-SHUN THERMAL POWER PLANT (TAIKANTON 1)

	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
	None	Heavy smoke from stacks A, B, D, F, G, H, and I. Moderate vapor from all cooling towers except C, F and G. Spray pond A has five units in operation. Ponds B, C, and E are in operation.
5X1	None	Heavy smoke from stack E. Moderate smoke from stack B, C and D. Possible smoke from stacks K and J. Heavy vapor from cooling tower A and and possibly B. Moderate vapor from cooling tower C. Light vapor from cooling towers M, L, J, H, and I. Spray ponds are activated.
	None	Heavy smoke from stack A. Moderate smoke from stacks B and C. Appears to be very dense vapor from all the cooling towers with the exception of A and B. Spray ponds are all activated.
	None	Heavy smoke from stack A. Moderate smoke from stacks B, C, D, E, and F. Light vapor from cooling towers A, B, H, and I. Spray ponds do not appear to be activated.
	None	Heavy smoke from stack A. Moderate smoke from three or four stacks (possibly C. E. G. and I). Heavy vapor from cooling towers E, D, and M. Moderate vapor from cooling tower J. Spray pond A is in operation. Half of spray pond B is in operation.

25X1

TOP SECRET Approved For Release 2003/06/20 : CIA-RDP78T05161A001100010048-5	25X1
CIA IMAGERY ANALYSIS DIVISION	25X1
	25X1
HUAN-JEN HYDRO POWER PLANT NPIC NUMBER - 119-C	25X1
The Huan-jen Hydro Power Plant is located on the Hun Chiang (River) 2.8 nm east of the Huan-jen Highway Bridge at coordinates 41 17 35N - 125 23 55E and is still incomplete. Construction was begun and has progressed little, if any, since that time. The dam completely spans the Hun Chiang and appears to be nearly finished. Housing for at least two turbo-generator units has been erected and the southern edge of the powerhouse appears unfinished indicating that additional	25X1 25X1

25X1 25X1


25X1

Approved For Release 2003/06/20 : CIA-RDP78T05161A001100010048-5


TOP SECRET

FIGURE 10

HUAN-JEN HYDRO POWER PLANT



25X1



25X1

25X1

25X1


TOP SECRET Approved For Release 2003/06/20 : CTA-RDP78T05161A001100010048-5	25X1
CIA IMAGERY ANALYSIS DIVISION	25X1 25X1
KAI-YUAN THERMAL POWER PLANT (CH'ING-HO) NPIC NUMBER - 40-C	25X1
The Kai-yuan Thermal Power Plant (Ch'ing-ho), also known as Sun-chia-tai, is located 7.5 nm east of Kai-yuan Airfield at coordinates 42 32 40N - 124 09 30E and has been in an arrested state of construction since first observed	25X1
If this plant is completed it will be rail-served, coal-operated and capable of housing at least four boiler-generator units. At present, it is large enough to house two boilers and two generators; however, the	:
absence of coal-conveying and processing buildings and switching and transmitting facilities makes the plant totally inoperable. Footings and	25X1
uprights for an addition to the powerhouse have been in place This will double the present plant area when completed.	25X1

25X1

25X1

Approved For Release 2003/06/20 CIA-RDP78 05161A001100010048-5 FIGURE 11

KAI-YUAN THERMAL POWER PLANT (CH'ING-HO)



25X1

25X1 25X1

Approved For Release 20090816851 CIA-RDP 8T05161A001100010048-5

TOP SECRET Approved For Release 2003/06/20 : CIA-RDP78T05161A001100010048-5	25X1
CIA IMAGERY ANALYSIS DIVISION	25X1
	25X1

LU-TA THERMAL POWER PLANT (AMANOGAWA 1) NPIC NUMBER - 18-S

Lu-ta Thermal Power Plant (Amanogawa 1) is located approximately 3.5 nm south of Chou-shui-tzu Airfield at coordinates 38 54 20N - 121 34 40E. The plant is rail-served, coal-operated and includes a large spray pond, integrated control house, sub-station with at least three transformers, and numerous support/storage buildings.

The boilerhouse appears designed for at least three boiler units. The eastern section is equipped with a single longitudinal monitor, one centrally located dust-catcher, and a single metal roof-stack. The western boilerhouse section contains two closely spaced metal roof-stacks and a single metal roof-stack, suggesting two boiler units of different capacities. The generator hall has about 35 vents arranged (in no apparent pattern) in clusters of two, four, six or eight. No power cables could be detected.

No s	ignificant	construction	occurred	during	the	period	25X ²
							25X

25X1



25X1


Approved For Release 2003/INE/26/CRETA-RDP78T05161A001100010048-5

FIGURE 12

Lu-ta Thermal Power Plant (Amanogawa 1)



25X1



25X1

25X1

25X1

CIA IMAGERY ANALYSIS DIVISION

25X1

LU-TA THERMAL POWER PLANT (AMANOGAWA 1)

CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION	
None	Light smoke from stacks C and D.	
None	Light smoke from stack A.	
None	No smoke/vapor observed.	
		2
None	No smoke/vapor observed.	
None	Light smoke from stack B.	

5**_|**

Арр	roved For Release 250970566RETA-R	DP78T05161A001100010048-5
	CIA IMAGERY ANALYSIS DI	VISION
	LU-TA THERMAL POWER PLANT	(AMANOGAWA 1)
	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
	None	I.
	None	Moderate smoke from stacks B. Light activity at spray
	None	.

25X1 None Light smoke from stacks $\mbox{\bf A}$ and $\mbox{\bf B.}$ None No smoke apparent. None Light smoke from stacks A and B. Spray pond is in operation.

K

TOP SECRET Approved For Release 2003/06/20 : CIA-RDP78T05161A001100010048-5	25X1
CIA IMAGERY ANALYSIS DIVISION	25X1
	25X1
LU-TA THERMAL POWER PLANT NO. 2 (KAN-CHING-TZU)	25X1

The Lu-ta Thermal Power Plant No. 2 (Kan-ching-tzu) is located 3.5 nm east of Chou-shui-tzu Airfield at coordinates 38 57 40N - 121 37 50E. The plant is rail-served, coal-operated, and includes two large and six small POL storage tanks, integrated control house, small water basin, and extensive coal handling and processing facilities.

NPIC NUMBER - 18-N2

The powerhouse has been expanded several times and presently consists of two main sections. The northern powerhouse section contains a boiler-house equipped with four transverse monitors and four metal roof-stacks, suggesting four boiler units. The generator hall contains a longitudinal monitor equipped with fourteen small vents, but has no power cables visible. The southern powerhouse section appears designed to accommodate four boiler units, although only three dust-catchers and three four-duct flues are installed. No power cables or other indicators of the number of generator units could be discerned.

No new construction occurred during the period 25X1

77




25X1

Approved For Release 2003/508/265CRETA-RDP78T05161A001100010048-5

LU-TA THERMAL POWER PLANT 2 (KAN-CHING-TZU)



25X1



25X1

CIA IMAGERY ANALYSIS DIVISION

CIX INVOCATIVATION OF THE CONTRACT OF THE CONT

LU-TA THERMAL POWER PLANT NO. 2 (KAN-CHING-TZU)

	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION	
	None	Heavy smoke precludes analysis.	
	None	Heavy smoke from stacks D, E, and possibly C.	
	None	Heavy smoke from stacks A, B, C, and D.	25X1
	None	Heavy smoke from stack E. Heavy clouds preclude further anal;	ysis.
	None	Heavy smoke from stacks D and E.	

-28

25X1

25X1

25X1

Approved For Release 250506ECRETA-RDP78T05161A001100010048-5

CIA IMAGERY ANALYSIS DIVISION

25X1 LU-TA THERMAL POWER PLANT NO. 2 (KAN-CHING-TZU)

	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
	None	Heavy smoke from stacks B, C, D, and E.
	None	Heavy smoke from stacks B, C, D, and E.
5X1	None	Heavy smoke from stacks B, C, D, and E.
	None	Moderate smoke from stack E obscure other stacks.
	None	Heavy smoke from stacks A, B, C, and D.

Approved	TOP SECRET For Release 2003/06/20 : CIA-RDP78T05161A0011 <u>00010048-5</u>	25X1
		25X1
	CIA IMAGERY ANALYSIS DIVISION	
		25X1
	PEN-CHI THERMAL POWER PLANT NO. 2	25X1

Pen-chi Thermal Power Plant No. 2 is located on the north bank of the Tai-tzu Ho (River) within the confines of the Manchu Iron Complex at coordinates 41 18 55N - 123 46 05E. The facility consists of two cooling towers, pumping station, possible control house and a number of small support/storage buildings. One of the cooling towers (A) is only one-half completed, but has been observed emitting vapor on all missions covering the plant. Coal handling and storage facilities were not present, suggesting that the plant may be gas fired. Coke-oven gas could be supplied from the steel complex.

NPIC NUMBER - 51-B1

The boilerhouse is equipped with three short metal roof-stacks and three probable vents, indicating three boiler units. The generator hall has a single longitudinal monitor; small scale coverage precluded detection of any power leads.


No new construction occurred during the period 25X1

25X1 25X1


25X1

Approved For Release 2003/06/20: C A-RDP78T05161A001100010048-5 FIGURE 14

PEN-CHI THERMAL POWER PLANT NO. 2



25X1



25X1

25X1

25X1

CIA IMAGERY ANALYSIS DIVISION

PEN-CHI THERMAL POWER PLANT NO. 2

CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION	
None	Poor quality photography precludes analysis.	
None	Moderate smoke from stack B. Light smoke from stack C. Light vapor from cooling towers A and B.	
		25X
None	Moderate smoke from stack A. Moderate vapor from cooling tower A.	
None	Moderate smoke from stack B. Heavy vapor from cooling tower A.	
None	Heavy smoke from stack B. Light vapor from cooling tower A.	
•		25X

2	5	>	(1

Approved For Release 2000 650 RDP78T05161A001100010048-5

25X1

CIA IMAGERY ANALYSIS DIVISION

25X1

PEN-CHI THERMAL POWER PLANT NO. 2

	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
	None	Heavy smoke from stack A. Heavy vapor from cooling tower A.
	None	Light smoke from stacks B and C. Heavy vapor from cooling tower A.
25X1	None	Light smoke from stacks A and C. Moderate vapor from cooling tower B. Light vapor from cooling tower A.
	None	Light smoke from stacks A and C. Light vapor from cooling tower A.
	None	Moderate smoke from stack A. Light vapor from cooling tower A.
	None	Moderate smoke from stack A. Moderate vapor from cooling tower A. Light vapor from cooling tower B.
	_	

25X1

Approved For Release 2002

RDP78T05161A001100010048-5

M

CIA IMAGERY ANALYSIS D	IVISION	
PEN-CHI THERMAL POWER E	· 3	

123 44 06E. The plant is rail-served and probably gas fired; a large pipeline connects the plant with the by-products coke plant located to the east. The power plant facilities include four natural-draft cooling towers, integrated control house, small adjacent sub-station with at least three probable transformers, and several unidentified support-type buildings.

The boilerhouse has four metal roof-stacks and four short longitudinal monitors, which suggest the presence of four boiler units. The generator hall is equipped with three longitudinal monitors and has three sets of power cables visible.

25X1 No new construction occurred during the period

Approved For Release 2003/d8/28ECRTA_RDP78 05161A001100010048-5

FIGURE 15

PEN-CHI THERMAL POWER PLANT NO. 3




25X1

25X1

25X1

25X1



25X1

25X1

CIA IMAGERY ANALYSIS DIVISION

25X1

25X1

PEN-CHI THERMAL POWER PLANT NO. 3

25X1

CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
None	Possible vapor from cooling tower A. Haze and obliquity precluded analysis.
None	Moderate smoke from stacks B and C. Light smoke from stack D. Light vapor from cooling towers A and B.
	25X1
None	Moderate smoke from stacks B and D. Light smoke from stack C. Moderate vapor from cooling tower B. Light vapor from cooling towers A, C, and D.
None	Apparent heavy smoke from stacks A, B, and C. Heavy vapor from cooling towers A and B. Moderate vapor from cooling towers C and D.
None	Moderate smoke from stacks B and D. Light vapor from cooling towers A and B.

-34-

5X1 5X1	Approved For Release 2 50	#0 &E6RET A-RDP78T05161A00110001004	8-5
 5X1	CIA IM	AGERY ANALYSIS DIVISION	
	PEN-CHI T	TERMAL POWER PLANT NO. 3	
:	CONSTRUCTION	ACTIVITY LEVEL OF PRO	DUCTION
	None	Heavy smoke from stace Other stacks obscured haze. Heavy vapor frower A. Light vapor towers C and D.	l by smoke/ com cooling
	None	Heavy smoke from stack smoke from stack B. from cooling tower B. vapor from cooling to D.	Heavy vapor Moderate
X1	None	Heavy smoke from all Light vapor from cool and D.	
	None	Moderate smoke from s D. Light smoke from Light vapor from cool C, and D.	stack D.
		Moderate smoke from a D. Heavy vapor from B and D. Light vapor towers A and C.	cooling tower

N

TOP SECRET Approved For Release 2003/06/20 : CTA-RDP78T05161A001100010048-5	25X1
	25X1
CIA IMAGERY ANALYSIS DIVISION	
	25X1

SHEN-YANG (MUKDEN) THERMAL POWER PLANT

NPIC NUMBER - 55-Y

The Shen-yang (Mukden) Thermal Power Plant is located in the northwest sector of Shen-yang, 2.0 nm east of Shen-yang Airfield West at coordinates 41 48 56N - 123 21 20E. The plant is rail-served, coal-operated and includes one large natural draft masonry cooling tower, control building with two visible transformers and coal processing and conveying facilities.

The boilerhouse appears presently capable of accommodating two boiler units, although the absence of one set of dust catchers indicates that only one boiler unit is installed. The boilerhouse section is connected to a single large masonry stack by two sets of flues (consisting of two ducts each). The generator hall is apparently not yet connected to the control house.

The present configuration of these facilities suggests that both the boilerhouse and generator hall may eventually be expanded. There has been no change in plant facilities since first observed and the plant has never been observed in operation.

25X1


25X1 25X1

25X1

Approved For Release 2003708/25CPEIA-RDP78FQ5161A001100010048-5

FIGURE 16

SHEN-YANG (MUKDEN) THERMAL POWER PLANT



25X1

25X1

TOP SECRET Approved For Release 2003/06/20 : CIA-RDP78T05161A001100010048-5	25X1
CIA IMAGERY ANALYSIS DIVISION	25X1
	25X1

The Shen-yang (Mukden) Thermal Power Plant NE is located in the northern section of Shen-yang at coordinates 41 48 40N - 123 26 28E. The plant is rail-served and coal fired. The facility consists of a natural draft cooling tower, a second cooling tower which is partially constructed, a cooling pond with three sprinkler units, a sub-station and control house, and numerous support/storage buildings not usually associated with a thermal power plant.

SHEN-YANG THERMAL POWER PLANT NE

The unique construction of the power plant makes an analysis difficult; however, the presence of one dust catcher unit and the single stack suggests that one boiler unit is installed. No cables are visible connecting the generator hall to the adjacent sub-station.

No new construction or plant activity was noted on ten photographic missions during the specified period $\hfill \square$

25X1

25X1

25X1


Approved For Release 20030605000010048-5

SHEW-YANG THERMAL POWER PLANT NE

FIGURE 17



25X1



25X1

25X1

P

Approved Fo	TOP SECRET or Release 2003/06/20 : CIA-RDP78T05161A00110	25X 00010048-5	(1
	CIA IMAGERY ANALYSIS DIVISION	25X	(1
		25>	< 1
	SUPUNG-NODONGJAGU HYDRO POWER PLANT	25X	(1

The Supung-Nodongjagu Hydro Power Plant is located at the mouth of the Shui-feng - Chu-shui-chih (revervoir) 8.5 nm northeast of the Chang-tien-ho Kou Highway Bridge at coordinates 40 27 25N - 114 52 40E, and consists of a large enlongated sub-station, a control house, a second small sub-station southeast of the facility, a water tower, and several support/storage buildings.

The generator hall is serviced by seven penstock intake-gates and has fourteen tailwater outlets, indicating that the plant might be designed to accommodate seven turbo-generators. Thirteen probable transformers are positioned on the downstream side of the generator hall; there are three sets of three and four single transformers. No power leads were visible between the sub-station and transformers.

25X1 No new construction occurred during the period

25X1


25X1

Approved For Release 2003/06/20 : CA-RDP78T05161A001100010048-5

TOP SECRET FIGURE 18

SUPUNG-NODONGJAGU HYDRO POWER PLANT

25X1



25X1

25X1

25X1

25X1

CIA IMAGERY ANALYSIS DIVISION

SUPUNG-NODONGJAGU HYDRO POWER PLANT

•	CONSTRUCTION ACTIVITY	LEVEL OF PRODUCTION
:	None	Moderate turbulence from three areas.
•	:	
	None	Heavy turbulence from two areas.
•		
	None	Heavy turbulence from one area. Light turbulence from two areas.
:		25X1
	None	Heavy turbulence from one area.
:	None	Heavy turbulence from one area. Light turbulence from two areas.

X1 X1	Approved For Release 2008/03/20	Approved For Release 2008/08/2016 RDP78T0516 1A001100010048-5	
X1	CIA IMAGERY A	MALYSIS DIVISION	
	SUPUNG-NODONGJAG	U HYDRO POWER PLANT	
	CONSTRUCTION ACTIV	VITY LEVEL OF PRODUCTION	
	None	Heavy turbulence from two areas.	
	None	Moderate turbulence from one area. Light turbulence from two areas.	
	None	Heavy turbulence from one area. Moderate turbulence from one area. Light turbulence from one area.	
K1	None	Moderate turbulence from three area	
	None	Heavy turbulence from two areas.	
	None	Heavy turbulence from two areas.	